




CI/SfB

(31.59) Hn6

Assured Data Sheet

ADS 022/02

FINGERSAFE SAFETY DEVICE



Fingersafe, when installed on the hinge side of the door, will protect fingers and hands from entrapment.

Marketing company (UK)

Fingersafe GB Ltd
8 Totman Close
Brook Road Industrial Estate
Rayleigh, Essex SS6 7UZ
Tel: +44 (0) 1268 777733
Fax: +44 (0) 1268 745800
e-mail: safety@fingersafe.com
website: www.fingersafe.com

Product description

Fingersafe is a finger safety device for hinged doors, made from PVC-U and TPE (Thermo Plastic Elastomer) material.

The products are available in kit form to suit doors up to 2032 mm high, but are also available, to order, in any lengths.

Use

Fingersafe is available in two versions. The MK1A is designed to act as cover for the gap created between a frame stop and a door hinge edge when the door is opened and comprises a fixing strip and a pleated guard. The MK1B is designed to act as a cover for the gap created between the door frame and the door leaf on the hinge pin side when the door is closing. Both are attached using steel screws.

Data

An assessment was carried out to determine the ease of installation and performance in use.

The opinions given apply to the product as assessed by the BBA under the contract leading to the issue of this Assured Data Sheet.

Technical opinion

In the opinion of the BBA, Fingersafe installed in accordance with the manufacturer's instructions is satisfactory as a finger safety device for hinged doors, and will have a satisfactory life.

On behalf of the BBA

Date: 22nd April 2002

Chief Executive

In issuing this Assured Data Sheet, the BBA does not accept responsibility to any person or body for any loss or damage, including personal injury, arising as a direct or indirect result of the use of these products.

British Board of Agrément
P O Box 195, Bucknalls Lane,
Garston, Herts WD25 9BA
Tel: 01923 665300
Fax: 01923 665301
e-mail: mail@bba.star.co.uk
website: www.bbacerfs.co.uk

Assured Data Sheets are not the same as Agrément Certificates. They relate to non-critical products for which there are generally no statutory requirements, and continuing surveillance of the production facility is not undertaken.

Readers are advised to check the validity of this Assured Data Sheet by contacting the BBA (Telephone Hotline 01923 665400).